

Drum Ceiling


RENAISSANCE

16"


24"

32"


Sloped Trim



RIC1090




RIC1092




RIC1094


Stepped Trim



RIC2000



RIC2002



RIC2004

Specifications:

- Trim rings are spun from .063" thick base material (brass or aluminum) or 18 gauge steel (plated or painted).
- Chassis is formed from 18 gauge cold-rolled steel.
- Formed acrylic bowl with a minimum wall thickness of .118". Opal finish is standard.
- Integral fluorescent ballasts are HPF electronic with low harmonic distortion.
- Ballasts are thermally protected and have Class "A" sound rating.
- Backplate attaches to standard 4" octagonal junction box.
- UL listed (US and Canada) for damp locations. (Not recommended for exterior use.)



RIC1094

Chrome Plated Polished Brass



RIC2004

Brushed Solid Brass



Sample model number: **RIC1094 - 3F39 - 120 - BAL - HP02**

Select Style	Select any Lamping (indirect/bowl illumination)	Lamping Detail (indirect - bowl illumination)	Optical Pkg. Photometry	Select Voltage	Select Finish	Select Options
16" RIC1090 RIC2000	2F13	(2) CFQ13W/G24q	A NA	120 277	PT__ Painted. (Include Paint Number.) PBR Polished solid brass BBR Brushed solid brass ABR Antique solid brass CPBR Chrome plated polished brass BAL Brushed aluminum ABST Antique brass over steel BBST Brushed brass over steel CPST Polished chrome over steel PBST Polished brass over steel <i>See Finish Selection Guide, pages 268-269.</i>	SP Spacer canopy (Not available for RIC1094 and 2004.) F Fuse option (M and F) RPI Remote ballast support tray EMI¹ Emergency ballast(s) integral EMR Emergency ballast(s) remote SBA Sandblasted acrylic HP01 Silver hand-painted acrylic HP02 Beige hand-painted acrylic HP03 Amber hand-painted acrylic FIN Finial option
	2F26	(2) CFQ26W/G24q	A NA			
	1N60	60W A19 INC	B E433-35			
	1F22	22W CIRC T5	C NA			
24" RIC1092 RIC2002	3N60	(3) A19 INC	D NA	PT__ Painted. (Include Paint Number.) PBR Polished solid brass BBR Brushed solid brass ABR Antique solid brass CPBR Chrome plated polished brass BAL Brushed aluminum ABST Antique brass over steel BBST Brushed brass over steel CPST Polished chrome over steel PBST Polished brass over steel <i>See Finish Selection Guide, pages 268-269.</i>	SP Spacer canopy (Not available for RIC1094 and 2004.) F Fuse option (M and F) RPI Remote ballast support tray EMI¹ Emergency ballast(s) integral EMR Emergency ballast(s) remote SBA Sandblasted acrylic HP01 Silver hand-painted acrylic HP02 Beige hand-painted acrylic HP03 Amber hand-painted acrylic FIN Finial option	
	1N150	150W A21 INC	E NA			
	3F13	(3) CFQ13W/G24q	F E433-34			
	2F26¹	(2) CFQ26W/G24q	G NA			
	2F39¹	(2) FT39W/2G11	G NA			
	1F40	40W CIRC T5	C NA			
32" RIC1094 RIC2004	3F39	(3) FT39W/2G11	H NA	PT__ Painted. (Include Paint Number.) PBR Polished solid brass BBR Brushed solid brass ABR Antique solid brass CPBR Chrome plated polished brass BAL Brushed aluminum ABST Antique brass over steel BBST Brushed brass over steel CPST Polished chrome over steel PBST Polished brass over steel <i>See Finish Selection Guide, pages 268-269.</i>	SP Spacer canopy (Not available for RIC1094 and 2004.) F Fuse option (M and F) RPI Remote ballast support tray EMI¹ Emergency ballast(s) integral EMR Emergency ballast(s) remote SBA Sandblasted acrylic HP01 Silver hand-painted acrylic HP02 Beige hand-painted acrylic HP03 Amber hand-painted acrylic FIN Finial option	
	3F39DM	(3) FT39W/2G11	H NA			
	4F39	(4) FT39W/2G11	I NA			
	3N100	(3) 100W A19 INC	D NA			

DM = Dimming ballast(s) provided

¹Denotes lamping options available with **EMI** (Requires **SP**-Spacer canopy)

If Photometry is not available, consult factory for further details.

For further detail on options, see Technical Notes on page 264.

OPTICAL PACKAGES

