

## **TEST REPORT**

**DATE: 03/17/2009 TEST NUMBER**: 119972

CLIENT	Masland Carpets
--------	-----------------

DESCRIPTION OF TEST SAMPLE			
IDENTIFICATION	Masland Carpets		
STYLE NAME	Oblique		
STYLE NUMBER	T455		
CONSTRUCTION	Multi-Level Loop Pile		
ROLL NUMBER	1000028073		
BACKING	Vinyl		
REFERENCE			

## **GENERAL PRINCIPLE**

This test is designed to examine dimensional changes in textile floor coverings due to various conditions of heat and moisture. Measurements are taken in the length and cross directions of the test sample after each treatment. A change in the dimension of the test sample is calculated as a percentage of the original preconditioned sample measurement. Shrinkage is indicated by a negative quotation while expansion is indicated by a positive quotation.

## **TEST RESULTS**

	Measurement	Percent		Measurement	Percent
Mo	24.0235		C <sub>0</sub>	24.0275	
M <sub>T1</sub>	24.0290	+0.023%	C <sub>T1</sub>	24.0295	+0.008%
M <sub>T2</sub>	24.0195	-0.017%	C <sub>T2</sub>	24.0275	+0.000%
M <sub>T3</sub>	24.0240	+0.002%	Стз	24.0305	+0.012%
M <sub>T4</sub>	24.0270	+0.015%	C <sub>T4</sub>	24.0330	+0.023%

Mο	Original measurement in machine direction		
C <sub>0</sub>	Original measurement in cross direction		
T <sub>1</sub>	Two hours in drying oven at 60° C		
T <sub>2</sub>	Two hours submerged in 0.1% detergent solution at 20°C		
T <sub>3</sub>	Twenty four hours in drying oven at 60°C		
T <sub>4</sub>	Forty eight hours conditioning at 20°C and 65% relative humidity		

APPROVED BY: Lang Utliny

This report is provided for the exclusive use of the client to whom it is addressed. It may be used in its entirety to gain product acceptance from duly constituted authorities. This report applies only to those samples tested and is not necessarily indicative of apparently identical of similar products. This report, or the name of Professional Testing Laboratory Inc. shall not be used under any circumstance in advertising to the general public.

714 Glenwood Place Dalton, GA 30721 Phone: 706-226-3283 Fax: 706-226-6787 email: protest@optilink.us