

The RND luminaire is available in two, three and four foot diameters with a precision spun ceiling trim. The recessed housing is engineered so that housing can be placed through the round aperture opening and assembled without any delay in ceiling finishing. The luminaire is uniformly illuminated with .125" thick white acrylic concaved lens with optional convex and flat lens. The RND is recommended for applications in open spaces, airport concourses, schools, retail and offices.

Housing: Die formed two-piece square housing for flanged fixture and one piece for grid, constructed of 20 gauge cold rolled steel finished in baked white enamel. Housing has four 7/8" knockouts at corners of housing top for access. Flanged housing has a mounting angle 14" long on two sides for mounting rods (supplied by others). Grid housing has four holes at corners on top of housing for tie wire (supplied by others)

Trim: A plaster ring is supplied when fixture is mounted to dry wall or plaster ceiling. The circular face trim is provided to mount the circular doorframe.

Reflector: Die formed 20-gauge cold rolled steel 90% minimum reflectivity finished in low glare matte baked white enamel **Shielding:** A white translucent acrylic diffuser is vacuum formed to permanently retain its concave dimension. The circular door frame twist locking clips permit hanging without tools, for relamping and cleaning.

Mounting: Standard installation is for two, three or four foot circular drywall ceiling. Optional trim is available for installations in grid ceiling. For mounting detail information consult factory.

Finish: Fixture housing and steel components are finished in baked white enamel applied over a five-stage pretreatment process. **Lamps:** Fixtures are provided for use with T8, T5, T5HO or compact fluorescent lamps. (Supplied by Others)

Certification: Luminaires are U. L. Listed, C. S. A. certified and are Union Made in the United States of America I.B.E.W.

| MODEL NO. | NOMINAL DIAMETER | SHIELDING | NO. OF LAMPS | LAMP SIZE | MOUNTING | FINISH | VOLTAGE | OPTIONS |
|-----------|---|---------------------------------------|-----------------------|--------------------------|---|--|--------------|-------------------------|
| NAS-RND | | - | _ | - | _ | - | _ | - 🔲 |
| NAS-RND | 2 = 2 ft 3 = 3 ft 4 = 4 ft | CC= Concave CX= Convex FL= Flat | 2 3 4 6 8 | T8 T5 T5HO 40CF | G= Standard Lay-in Grid MG= Miniature Grid F= Flanged | W = White CC = Custom Color | 120v 277v | See Options Below |
| | | | | O =Other Specify | See Accessories | | | |

Example: NAS-RND-4CC-632T8-F-W-120V

New Age Round four foot diameter with six 32 watt T8 lamps flanged fixture finished in baked white enamel, with concave white acrylic diffuser, 120 volt electronic ballast less than 20% harmonics.

E10= Electronic ballast, high power factor, thermally protected class P, sound rated A, < 10% total harmonic distortion

DIM= Dimming Ballast

EPC= Emergency Battery Pack


EMC= Emergency Circuit

TCW= Two Circuit Wiring

OTH= See Accessories for other options available




MOUNTING "G"




STD. 1 1/2" INVERTED "T" BAR

MOUNTING "MG"



1 1/2" MINIATURE GRID CEILING


MOUNTING "F"



* PLASTER OR DRY WALL CEILING


* FIXTURES INSTALLED IN PLASTER OR DRY WALL REQUIRES PLASTER RING AND THE HOUSING IS SHIPPED IN TWO SECTIONS


2



- (1) SECURED PLASTER FRAME TO THE CEILING WITH RODS OR WIRE TIES. THE PLASTER FRAMES ARE SHIP PRIOR TO THE FIXTURE FOR CEILING PREPARATION.
- (2) INSERT THE FIXTURE SECTIONS ONE AT A TIME. THE FIXTURE HOUSING IS FABRICATED IN TO MATING SECTIONS TO ALLOW ENTRY THROUGH THE PLASTER FRAME APERATURE, THE HOUSING IS FURNISHED WITH THE NECESSARY HARDWARE FOR FIELD ATTACHMENT.
- (3) INSTALL THE LENS FRAME ASSEMBLY TO THE FIXTURE HOUSING. THE LENS FRAME IS PROVIDED WITH HARDWARE AND IS TETHERED TO ALLOW ACCESS INSIDE THE FIXTURE. THE LENS DOOR IS SECURED WITH A BAYONET LOCKING ACTION.







270)

LAMP (3) 40W C.F. LUMENS: 3150 PER LAMP

Candela Distribution:

| Angle | 0 | 90 | 180 | 270 | 360 |
|-------|------|------|------|------|------|
| 0 | 1971 | 1971 | 1971 | 1971 | 1971 |
| 5 | 1911 | 1820 | 1727 | 1763 | 1911 |
| 10 | 1984 | 1914 | 1738 | 2010 | 1984 |
| 15 | 1912 | 1900 | 1765 | 1835 | 1912 |
| 20 | 1779 | 1799 | 1580 | 1807 | 1779 |
| 25 | 1681 | 1692 | 1429 | 1629 | 1681 |
| 30 | 1512 | 1615 | 1407 | 1612 | 1512 |
| 35 | 1466 | 1425 | 1245 | 1407 | 1466 |
| 40 | 1283 | 1277 | 1122 | 1262 | 1283 |
| 45 | 1098 | 1112 | 993 | 1145 | 1098 |
| 50 | 892 | 834 | 736 | 1017 | 1019 |
| 55 | 892 | 834 | 736 | 876 | 892 |
| 60 | 664 | 723 | 671 | 688 | 664 |
| 65 | 543 | 551 | 507 | 552 | 543 |
| 70 | 413 | 373 | 358 | 376 | 413 |
| 75 | 256 | 246 | 239 | 279 | 256 |
| 80 | 142 | 141 | 134 | 145 | 142 |
| 85 | 43.4 | 38.0 | 44.8 | 46.3 | 43.4 |
| 90 | 0.00 | 0.78 | 0.92 | 2.32 | 0.00 |
| | | | | | |

Optical Distribution:

Coefficients of Utilization - Zonal Cavity Method:

pfc = 0.20

| pcc | .8 .7 .5 .3 .1 | .7 .7 .5 .3 .1 | .5 .5 .3 .1 | .3 .5 .3 .1 | .1 .5 .3 .1 | 0 |
|-----|-------------------|-------------------|----------------|----------------|----------------|----|
| RCR | | ., ., ., ., | .5 .5 .1 | .5 .5 .1 | .5 .5 .1 | 0 |
| 0 | 60 60 60 60 | 59 59 59 59 | 56 56 56 | 54 54 54 | 51 51 51 | 50 |
| 1 | 55 53 51 49 | 54 52 50 48 | 50 48 47 | 48 47 45 | 46 45 44 | 43 |
| 2 | 50 46 43 40 | 49 46 42 40 | 44 41 39 | 42 40 38 | 41 39 37 | 36 |
| 3 | 46 41 37 34 | 45 40 36 34 | 39 36 33 | 37 35 32 | 36 34 32 | 31 |
| 4 | 42 36 32 29 | 41 36 32 29 | 34 31 28 | 33 30 28 | 32 30 27 | 26 |
| 5 | 39 33 28 25 | 38 32 28 25 | 31 27 24 | 30 27 24 | 29 26 24 | 23 |
| 6 | 36 29 25 22 | 35 29 25 22 | 28 24 21 | 27 24 21 | 26 23 21 | 20 |
| 7 | 33 27 22 19 | 33 26 22 19 | 25 22 19 | 25 21 19 | 24 21 19 | 18 |
| 8 | 31 24 20 17 | 30 24 20 17 | 23 20 17 | 23 19 17 | 22 19 17 | 16 |
| 9 | 29 22 18 15 | 28 22 18 15 | 21 18 15 | 21 18 15 | 20 17 15 | 14 |
| 10 | 27 21 17 14 | 27 20 17 14 | 20 16 14 | 19 16 14 | 19 16 14 | 13 |
| | | | | | | |





---- 180