


**Building Mount**  
**6" Dia.**  
**Corridor**  
**Walkways**  
**Accent**  
**Building Entrances**



### Specifications



#### Certifications

The fixture shall be ETL and CETL listed for wet location.

#### Ballast Housing

Cast aluminum with a minimum thickness of 1/8". Mounting plate welded to ballast housing for J-box mounting. Housing is fully gasketed with 3/16" extruded EDPM cord gasket.

#### Lens Frame

Cast aluminum mounted to ballast housing with 1/4-20 stainless steel allen cap screws.

#### Lens

Opal UV-stabilized polycarbonate (OP) is standard. Lens supplied with one-piece extruded silicone gasket.

#### Ballast

Fluorescent ballasts for 2-D lamp is electronic (minus 20° C).

#### Finish

BK-BZ-WH-GR-GY-NA baked enamel standard, other colors available.

### Product Order Guide

Series	Max Watts	Lamp Type	Voltage <sup>1</sup>	Lens	Finish <sup>1</sup>
BL-35	10 Watt 2-D	10W-2D	120	OP Opal Polycarbonate	BK Black BZ Bronze WH White GR Green NA Natural Aluminum GY Gray CC Custom Color

<sup>1</sup> Consult factory for other colors and voltages

PROJECT
FIXTURE TYPE
CATALOG#