

Cerra® 10

Indirect T8

Type:

Project:

SPECIFICATIONS

Modular / 10" x 3"

10CRM1


CATALOG NUMBER

FT


Examples: 10CRM1 2 32 WHR 40FT R12 277 GEB DCT LP735 F1/18 SCEP — 10CRM1 3 32 SPR 32FT R8 277 GEB 1SE EL DCT LP735 F1/21

AVAILABLE FIXTURES


□ 10CRM1 - 1




□ 10CRM1 - 2



□ 10CRM1 - 3



□ 10CRM1 - 4



SPECIFICATIONS

Construction

Housing is a nominal 10" x 3" crescent channel formed from one-piece cold-rolled steel. Flat end plate standard. Sculptured die cast aluminum end cap is optional.

Reflectors

Die-formed highly reflective white reflector or die-formed highly reflective specular reflector.

Finish

Fine textured white polyester powder paint is standard. Consult factory for special finish requirements.

Electrical

Specify 120, 277 or 347 volts. Pre-wired with 16 ga. fixture wire. For special circuiting or wire gauge, consult factory. Plug-in electrical connectors included. C-UL label standard.

Fixture Length

4', 8', and 12' lengths in a single section for exact suspension spacing of 4', 8', and 12'. For total fixture length, add 1/8" for each flat end plate or 4" for each sculptured end cap. Using internal joiners, 4', 8', and 12' sections can be joined to form longer length fixtures.

ORDERING LOGIC

Use guide below to order complete fixture runs from four feet to one-hundred feet in increments of four.

| FT | | | | | | | | |
|--|-----------------------------|---|--|---|------------------------|--|---|---|
| Fixture | # of Lamps in Cross Section | Lamp Type | Reflector | Nominal Overall Row Length ¹ | Maximum Section Length | Voltage | Ballast Type | # of Emergency Modules ² |
| 10CRM1 | 1 2 3 4 | 32 | WHR White Reflector (Standard) SPR Specular Reflector | | R4 R8 R12 | 120 277 347 | GEB10 <10% THD ELECTRONIC ADEZ ⁴ Advance Mark 10 dimming ECO10 ⁴ Lutron ECO-10 dimming ADZT ⁴ Advance Mark 7 0-10v dimming <i>Reference Ballast Chart on website or consult factory for other options.</i> | Blank No Emergency 1SE 1 Section 2SE 2 Sections XSE X Sections |
| / | | | | | | | | |
| Emergency Type ^{2,3} | Switching | Lamp Color | Mounting Type | Overall Suspension | | Finish | Options | |
| Blank No Emergency or Night Light | SCT Single Circuit | L/LP No Lamp LP730 3000k 70+ CRI | F1 T-Bar Ceiling (Universal Mounting Bracket) | 12 | 12" overall suspension | (blank) | ACG Adjustable Cable Grippers | |
| EL Emergency Battery Pack | DCT Dual Circuit | LP735 3500k 70+ CRI LP741 4100k 70+ CRI | F1A T-Bar Ceiling (UMB with Integrated J-Box) | 15 | 15" overall suspension | C110 Painted Silver to Match Anodized Aluminum | APF Alternate Power Feed | |
| EC Emergency/Night Light Circuit | | LP830 3000k 80+ CRI LP835 3500k 80+ CRI | F2 Hard Ceiling (Horizontal J-Box) | 18 | 18" overall suspension | C210 Textured White | CP Chicago Plenum | |
| EN Emergency Battery Pack with Night Light Circuit | | LP841 4100k 80+ CRI <i>Reference Lamp Chart on website or consult factory for other options.</i> | F3 Stem Mount F4A IDS Clip 1/8" Tee F4B IDS Clip 1/4" Tee F4C IDS Clip Screw Slot | 21 | 21" overall suspension | ELH White (low gloss) | DL Damp Location Label | |
| | | | | 24 | 24" overall suspension | C099 Custom Color | DU Dust Cover | |
| | | | | XX | XX" overall suspension | | ELM EM through wire/w separate feed ELS EM through wire/w single feed GLR Fusing (fast blow) GMF Fusing (slow blow) NYC New York City Code SCEP Sculptured End Cap | |

Notes:

- Must be in 4' increments.
- Optional.
- EL and EC are installed in last 4' of fixture sections and are not available concurrently with each other. Separate feed required for each EL or EC unless ELH is specified.
- Not available in 347 volt.