

ABSTRACT

TEST MATERIAL: **BAUHAUS TEXTURE**

TEST STANDARD: ASTM E84 Standard Test Method for SURFACE
 BURNING CHARACTERISTICS OF BUILDING
 MATERIALS (ANSI 2.5, NFPA 255, UBC 42-1,
 UL 723)

TEST DATE: May 19, 1997

TEST RESULTS: **FLAME SPREAD INDEX** **15**
 SMOKE DEVELOPED INDEX **0**

According to the standard classification system cited by building codes, this fabric is:

Class A or I

Standard Classification System:

<u>Class</u>	<u>Flame Spread Index</u>	<u>Smoke Development Rating</u>
1 or A	0 - 25	450 maximum
2 or B	26 - 75	450 maximum
3 or C	76 - 200	450 maximum

The description of the test procedure and specimen evaluated, as well as the observations and results obtained, contained herein are true and accurate within the limits of sound engineering practice. These test results were obtained from an outside source. A copy of the original document is kept on file at Applied Textiles.