

TABLE I - DESCRIPTION OF MATERIAL TESTED

Identification	- Mohair Velvet
Type Material	- Fabric
Total Weight	- 18.6 ounces per square yard

TABLE II - TEST RESULTS

<u>Test Specimen</u>	<u>Flame Spread Index</u>	<u>Smoke Density Developed</u>
GRC board	0	0
red oak flooring	100	100
Mohair Velvet	20	5

Although deleted from the Standard in 1977, some agencies may require Fuel Contribution for approval of a material. While ASTM E 84-86 makes no provision for measuring Fuel Contribution, it may be calculated in accordance with E 84-75. For the material tested, Fuel Contribution is 0 when calculated in this manner.

TABLE III - OBSERVATIONS DURING TESTING

Ignition over the burners was noted at 0.20 minutes. The flame front advanced to a maximum of 4.5 feet at 0.36 minutes with a maximum temperature recorded during the test of 576°F.