

**Flame Certificate**  
Time 300 by Kvadrat  
283687

**maharam**

Time 300 by Kvadrat was tested and met the following flammability requirements:  
Upholstered Walls: ASTM E 84 Unadhered flame 5, smoke 60  
Windows: NFPA 701

Contact [clientservices@maharam.com](mailto:clientservices@maharam.com) with any questions.