

Flame Certificate

Tosca

399458

maharam

Tosca was tested and met the following flammability requirements:

Walls: ASTM E 84 Adhered flame 25, smoke 15

Contact clientservices@maharam.com with any questions.