

Flame Certificate

Wood Wall As Safari Vest

399470

maharam

Wood Wall As Safari Vest was tested and met the following flammability requirements:

Walls: ASTM E 84 Adhered flame 25, smoke 15

Contact clientservices@maharam.com with any questions.