

Flame Certificate

IN DIRECT LINE WITH ANOTHER & THE NEXT
399527

maharam

In Direct Line With Another & the Next was tested and met the following flammability requirements:
Walls: ASTM E 84 Adhered flame 25, smoke 15

Contact clientservices@maharam.com with any questions.