

After approximately 15,000 uses, there will be a small amount of blue Odor Barrier Liquid on top of the Drain Insert. This indicates it is time to change out the Odor Barrier Liquid and the Drain Insert.



1. Using the key provided, screw the key into the key hole of the drain insert and fill with water.



2. Pull upward on insert to remove.



3. Rinse the open trap with water.



4. Replace the new insert, press down until you feel and hear a slight popping sound.



5. Fill with 32 ounces of water.



6. Pour into 1-10 ounce bottle of odor barrier liquid.

In Mexico:
Customer Service Manager
AS Maquila, S.A. de C.V.
Via Morelos #330
Col. Santa Clara
Ecatepec 55540 Eco. Mexico
www.americanstandard.com.mx

In Canada:
AS Canada ULC
2480 Stanfield Rd.
Mississauga, Ontario
Canada L4Y 1S2
Toll Free: (800) 387-0369
www.americanstandard.ca

In the United States:
American Standard Brands
P.O. Box 6820
Piscataway, New Jersey 08855
Attention: Director of Consumer Affairs
For residents of the United States, warranty information may also be obtained by calling the following toll free number: (800) 442-1902
www.americanstandard-us.com