


Notes: _____

Room size: **50'X50'X10' CEILING**

Reflectances: Ceiling 80%
Wall 50%
Floor 20%

REVIT files are available for download at www.axislighting.com




SHOWN WITH PL - LOUVER

CUBIC PENDANT


LUMINAIRE ARRANGEMENT

Work Plane Height: 2'6"
Calculation Grid: 20' x 20'


12' SPACING, 18" SUSPENSION




16' SPACING, 18" SUSPENSION




LIGHT DISTRIBUTION




LIGHT DISTRIBUTION



12' SPACING, 18" SUSPENSION



LIGHT DISTRIBUTION



NOTES

- Calculations were done without consideration of partitions or furniture. Depending on reflectances, resulting illumination will reduce by 15-25%.
- Lighting Power Density (LPD) considers the lamp & ballast combination used for testing. Other combinations will vary results.
- Light Loss Factor (LLF) is a product of lamp lumen depreciation, luminaire dirt depreciation and ballast factor.

i All IES files for other lamping are available for download at: www.axislighting.com