


Notes:

Reflectances:	Ceiling	80%
	Wall	50%
	Floor	20%

REVIT files are available for download at www.axislighting.com




CUBIC NARROW PENDANT

LUMINAIRE ARRANGEMENT

Work Plane Height: 2'6"
Calculation Grid: 20' x 20'

Room size: **50'X50'X12' CEILING**


16' SPACING, 24" SUSPENSION



CODE: CUB-PL-4-T5HO-1-X-0-2


Avg	40.20 fc
LPD	0.85 w/sq.ft
Max/Min	1.54
LLF	0.90
Ceiling uniformity	3.78

LIGHT DISTRIBUTION



Room size: **50'X50'X10' CEILING**


10' SPACING, 18" SUSPENSION



CODE: CUB-SB-4-T8-1-X-0-FP

Avg	43.80 fc
LPD	0.94 w/sq.ft
Max/Min	1.36
LLF	0.90
Ceiling uniformity	2.52

LIGHT DISTRIBUTION



NOTES

- Calculations were done without consideration of partitions or furniture. Depending on reflectances, resulting illumination will reduce by 15-25%.
- Lighting Power Density (LPD) considers the lamp & ballast combination used for testing. Other combinations will vary results.
- Light Loss Factor (LLF) is a product of lamp lumen depreciation, luminaire dirt depreciation and ballast factor.

i All IES files for other lamping are available for download at: www.axislighting.com