


Notes:

Room size: 50'X50'X10' CEILING

Reflectances:

Ceiling	80%
Wall	50%
Floor	20%

REVIT files are available for download at www.axislighting.com




PRIME ROUND PENDANT

LUMINAIRE ARRANGEMENT

Work Plane Height: 2'6"
Calculation Grid: 20' x 20'


12' SPACING, 24" SUSPENSION



CODE: PR-S-4-T8-1

Avg 45.8 fc
LPD 0.86 w/sq.ft
Max/Min 1.12
LLF 0.90

10' SPACING, 12" SUSPENSION



CODE: PR-S-4-T5-1

Avg 41.12 fc
LPD 0.58 w/sq.ft
Max/Min 1.32
LLF 0.90

NOTES

1. Calculations were done without consideration of partitions or furniture. Depending on reflectances, resulting illumination will reduce by 15-25%.
2. Lighting Power Density (LPD) considers the lamp & ballast combination used for testing. Other combinations will vary results.
3. Light Loss Factor (LLF) is a product of lamp lumen depreciation, luminaire dirt depreciation and ballast factor.

CODE: SL-VL-60/40-4-T5-1

i All IES files: T5, T5HO, T8, F25TT, F40TT, F50TT, and F55TT lamping are available for download at: www.axislighting.com