


Notes:

Reflectances:	Ceiling	80%
	Wall	50%
	Floor	20%

REVIT files are available for download at www.axislighting.com




PRIME WEDGE PENDANT

LUMINAIRE ARRANGEMENT

Room size: 50'X50'X12' CEILING

Work Plane Height: 2'6"
Calculation Grid: 20' x 20'

12' SPACING, 24" SUSPENSION



CODE: PW-S-4-T5-1


Avg	41.61 fc
LPD	0.58 w/sq.ft
Max/Min	1.32
LLF	0.90

LUMINAIRE ARRANGEMENT

Room size: 50'X50'X12' CEILING

Work Plane Height: 2'6"
Calculation Grid: 20' x 20'

16' SPACING, 24" SUSPENSION



CODE: PW-S-4-T5HO-1

Avg	44.69 fc
LPD	0.78 w/sq.ft
Max/Min	1.1
LLF	0.90

NOTES

1. Calculations were done without consideration of partitions or furniture. Depending on reflectances, resulting illumination will reduce by 15-25%.
2. Lighting Power Density (LPD) considers the lamp & ballast combination used for testing. Other combinations will vary results.
3. Light Loss Factor (LLF) is a product of lamp lumen depreciation, luminaire dirt depreciation and ballast factor.

CODE: SL-VL-60/40-4-T5-1

i All IES files: T5, T5HO, T8, F25TT, F40TT, F50TT, and F55TT lamping are available for download at: www.axislighting.com