

Flame Certificate

Meld

466387

maharam

Meld was tested and met the following flammability requirements:

Seating: California Bulletin #117-2013

Upholstered Walls: ASTM E 84 Unadhered flame 10, smoke 60

Contact clientservices@maharam.com with any questions.